



AMERICAN FLAMECOAT INC.

520 Eagleton Downs Drive - D  
 Pineville, NC 28134  
 O: 704.405.2550  
 F: 704.543.9772  
 www.americanflamecoat.com

thesign / E. STIEGER Company  
 NEUSEELAND 32  
 9404 RORSCHACHERBERG  
 SWITZERLAND

Pattern: THE SIGN - ARTICLE 30522 VELVETTINO – TREATED WITH FLAMECOAT  
 Report No.: 57227  
 Date: JULY 26, 2017

**TEST RESULTS**

**NATIONAL FIRE PROTECTION ASSOCIATION STD.701-2015 – TEST 1 Small Scale**

Specimen	Residues (seconds)	Weight loss (%)
1	1.1	24.5
2	0	21.75
3	0	20
4	0	20.9
5	0.99	24.5
6	0	19
7	0	20.25
8	0	21
9	0.89	22
10	1.1	24.5
Average	0.408	21.84

**Results: The Above Tested Material \*Meets\* the Requirement**

**Requirements:**

Average percent weight loss can-not exceed 40% and any individual Specimen can-not exceed mean value plus three standard deviations.

**Residue Flame:**

Shall not continue to flame after reaching the floor of the tester for more than an average of two seconds per specimen for the sample of 10 specimens.

Sincerely,

Brad Souffrant





AMERICAN FLAMECOAT INC.

520 Eagleton Downs Drive - D  
Pineville, NC 28134  
O: 704.405.2550  
F: 704.543.9772  
www.americanflamecoat.com

December 06, 2018

thesign / AG  
NEUSEELAND 32  
9404 RORSCHACHERBERG  
SWITZERLAND

Reference: Flammability Test Report: 80749

One (1) fabric sample identified as Article VELVETTINO 30522 treated with Flamecoat was received and tested in accordance with the National Fire Protection Association (N.F.P.A.) 260 “Standard Method for Cigarette Ignition Resistance of Components of Upholstered Furniture (2013 edition).” fabric classification test method. The results are as follows:

Test Results		
Vertical Char Lengths		
11mm	12mm	10mm

The sample **meets** the requirements of the above standards and may be considered a **Class I Cover Fabric**.

There were no ignitions on any of the three (3) specimens tested. In addition, none of the of the three test specimens displayed a vertical char which was equal to or greater than 45mm.

If there are any questions or when we can be of further assistance, please let us know.

Sincerely,

Brad Souffrant

